

From: NCC – Sab

Sent: 21 October 2025 15:41

To: NCC - Planning <Planning@newport.gov.uk>

Cc: NCC - Sab <Sab@newport.gov.uk>

Subject: RE: Planning Consultation Request for case ref: 25/0325

Good afternoon

Having reviewed the submitted information, a SAB application may not be required but if there are any external works exceeding 100square metres then we would encourage the applicant to visit

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.newport.gov.uk%2Fen%2FPlanning-Housing%2FPlanning%2FSustainable-drainage-systems.aspx&data=05%7C02%7CLydia.Burrows%40newport.gov.uk%7Ca55811e675cb4b361d5c08de112eda9d%7C2c4d0079c52c4bb3b3cad8eaf1b6b7d5%7C0%7C0%7C638967090111717569%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiJlZjAuMDAwMCIsIlAiOiJXaW4zMilslkFOljoiTWFpbCIsIlldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=mgx5Qr6Fg44kqRUhQnibbZsgLdrbjo42OFDCAbQtgtl%3D&reserved=0>

for further information, or contact the SAB team sab@newport.gov.uk for further discussions.

Kind Regards

NCC-SAB