

Newport County Council  
Civic Centre  
Newport  
NP20 4UR

**Date: 14/08/2025**  
**Our Ref: PLA0089135**  
**Your Ref: 25/0530**

Dear Sir/Madam

**Grid Ref: ST314870 331511 187088**

**Site: LAND AT 153 COMMERCIAL ROAD NEWPORT**

**Development: REDEVELOPMENT OF VACANT SITE TO PROVIDE A COMMERCIAL UNIT ON THE GROUND FLOOR AND 4 NO. STUDIO FLATS WITHIN THE FIRST AND SECOND FLOORS (RESUBMISSION OF 24/0373)**

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

This site is in close proximity of a public water mains with their approximate positions being marked on the attached statutory public sewer/watermain record. In accordance with the Water Industry Act 1991, Dwr Cymru Welsh Water requires access to its apparatus at all times in order to carry out maintenance and repairs. Having regard to drawing reference OS01, it appears the proposed development would be situated within the protection zone of the public assets measured 3.6 metres either side of the centreline. Please note, the distance specified for this protection zone is indicative and based on industry standard guidelines. However, the depth of the asset will need to be verified on site which may infer a greater protection zone. For completeness, we recommend the developer refer to their title deeds to confirm if there are any covenants or restrictions associated with the assets crossing the proposed development site.

In this instance, it appears there is sufficient space and scope to re-position the development outside the protection zone of the asset. Therefore, it is strongly recommended that the drawing reference OS01 is amended to take into account the location of the assets crossing the site and we respectfully request we are re-consulted on receipt of this information. It is also recommended that the developer contact our Plan and Protect team ([PlanandProtect@dwrcymru.com](mailto:PlanandProtect@dwrcymru.com)) to carry out a survey to verify the location of the assets and establish their relationship to the proposed development.

Accordingly, for the reasons outlined above, we offer a Holding Objection until such time as additional/amended information has been submitted and request we are re-consulted on receipt of this information.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at [developer.services@dwrwymru.com](mailto:developer.services@dwrwymru.com)

Please quote our reference number in all communications and correspondence.

Yours faithfully,

**Phillip Little**  
**Development Planning Officer**  
**Developer Services**



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.