

Date: 28 January 2024
Main Location: West Of England Hotel
42 Mill Parade
Newport
South Wales
NP20 2JS

Application Description: CONVERSION OF THE UPPER FLOORS OF EXISTING HOTEL TO CREATE 10NO. RESIDENTIAL APARTMENTS AND ASSOCIATED EXTERNAL AND INTERNAL WORKS

Planning reference number: 23/0703

Planning case officer: Jacob Cooke

I refer to the above application passed to the Noise and Neighbourhood Team for comment.

I confirm I have reviewed the submitted Acoustic assessment, dated 22nd Aug 2023.

We have no objection to the proposed development, subject to inclusion of the following conditions;

Construction Environmental Management Plan

No development shall take place until a site specific Demolition and Construction Environmental Management Plan has been submitted to and been approved in writing by the Council. The plan must demonstrate the adoption and use of the best practicable means to reduce the effects of noise, vibration, dust and site lighting. The plan should include, but not be limited to:

- Procedures for maintaining good public relations including complaint management, public consultation and liaison
- Arrangements for liaison with the Newport City Council Noise & Neighbourhood Team
- Deliveries to and removal of plant, equipment, machinery and waste from the site must only take place within permitted hours
- Mitigation measures as defined in BS 5228: Parts 1 and 2 : 2009 Noise and Vibration Control on Construction and Open Sites shall be used to minimise noise disturbance from construction works.
- Procedures for emergency deviation of the agreed working hours.
- Measures for controlling the use of site lighting whether required for safe working or for security purposes.
- Measures to mitigate demolition dust and material causing a nuisance to local residents, for example sheeting of loads and wheel washing apparatus

Reason: To protect the amenities of occupiers of other premises in the vicinity

Development/Construction Hours

To protect the amenity of existing residents, I would recommend that there is no arrival, departure, loading or unloading of vehicles, development and/or construction (including land raising and demolition if required) occurs outside the hours of 08.00 and 18.00 Monday to Friday and between the hours of 08.00 and 13.00 on Saturdays. There shall be no development on Sundays or Bank Holidays.

Noise Insulation

Prior to first occupation, a scheme of sound insulation works to the floor/ceiling/party wall structures between the properties shall be implemented in accordance with details that have first been submitted to and approved in writing by the Local Planning Authority. The approved scheme shall be retained thereafter in perpetuity.

Reason: To ensure that the amenities of occupiers of other premises in the vicinity are protected.

Waste storage and Recycling

Prior to first beneficial use, a scheme for the provision of waste storage and recycling shall be submitted to and approved in writing by the local planning authority. The approved scheme shall be implemented prior to first beneficial use and thereafter maintained for the duration of the use.

Reason: To ensure that the amenities of occupiers of other premises in the vicinity are protected

Advisory:

If Air Source Heat Pumps (ASHPs) are intended to be installed in the residential scheme for sustainable heating source; further acoustic impact information will be required, including an environmental noise assessment to consider the cumulative impact of multiple ASHPs. Further information is available from the Environmental Protection team.

Officer name:	James Holland
Officer Email:	james.holland@newport.gov.uk
Officer Contact number:	01633 414720
SRT Number:	23/12344/ABRPFA