

From: McWilliam, Garth (Landscape Architect) <Garth.McWilliam@newport.gov.uk>
Sent: 30 July 2025 09:24
To: Quinn, Vicky (Senior Planning Officer) <Vicky.Quinn@newport.gov.uk>
Cc: gill@mackleydavies.co.uk; Williams, John (Team Manager - Countryside & Conservation) <John.Williams@newport.gov.uk>
Subject: RE: Application ref. 24/0563

Hi Vicky,

The information on the block/location plan does not address any of my original comments, other than suggesting some notional planting of which the specification and details are insufficient. Therefore, it is unacceptable.

Plug planting is usually specified for marginal/aquatic locations therefore inappropriate and although the native hedge mix would be welcome, there is insufficient detail on sizes and spacing.

Please refer the applicant to my original comments, attached FYI.

Goreu / Best,

Garth McWilliam BSc(Hons) PGDip CMLI BwN

Landscape Architect / Officer

Cefn gwlad a Chadwraeth/ Countryside & Conservation

Cyngor Dinas Casnewydd / Newport City Council

Rhif ffôn / Phone number: 07483 488 154

Please note that I work only Wednesday - Friday