

25/0866

77 The Uplands

Rogerstone

NP10 9FE

We would object due to the lack of tree information provided, there are trees close to the area of development and so a BS5837 compliant tree survey and a constraints plan are required to prove there will be no impact on the trees due to or in the course of development.

The Survey needs to be undertaken by a competent and qualified Tree Consultant.