



HS10: Noise assessment

Contract/Job Name	Somerton Car Wash, Newport
Contract/Job Number	Garage Demolition, Cromwell Rd, Newport
Description of Task & Tools/Plant/Equipment being Assessed	
Date	
Assessment Carried Out By	

1 Introduction

Noise assessments will be carried out for each task where judged to be necessary, in accordance with the Control of Noise at Work Regulations 2005. The Health & Safety Executive recommends an assessment is necessary in any situation where people have difficulty hearing one another when 2 metres apart. Tasks requiring Noise Assessment may include but are not limited to asphalt paving, blasting, carpentry, drilling / chipping / grinding / finishing concrete, crushing, driving crawler tractor / dumper / excavator / grader / loader / roller / wheeled tractor / wheeled loader, pouring, digging, scabbling, shovelling hardcore, guniting, shuttering, piling, sandblasting, reinforcing and any other use of air-compressed tools.

All operatives who may be affected by the noise assessed in this document will be informed of the risks, given appropriate PPE and be informed of any other control measures they need to implement. Where appropriate, health surveillance i.e. hearing tests will be put in place.

2 Pre-site assessment

	Yes	No
Is the equipment to be used the quietest available option?	☐	☐
Is there an alternative quieter method to carry out this task?	☐	☐
Can this task be carried out when there are reduced numbers of personnel on site?	☐	☐
Can this task be carried out when other noisy tasks are being carried out to minimise the length of time that personnel and the public are exposed to excess noise levels?	☐	☐
Does this task involve fabrication that could be carried out in a different location?	☐	☐

3 On-site assessment

	Indoors	Outdoors	Confined Space
Where is this task being carried out? / Where is this tool / machine being used?	☐	☐	☐

4 On-site assessment

The level of noise is probably less than 80dB(A) ☐

The level of noise is more than 80dB(A) but probably less than 85dB(A) ☐

The level of noise is likely to be more than 90dB(A) but probably less than 95dB(A) ☐

No action required	☐
Hearing Protection is available	☐
Hearing Protection MUST be worn	☐
Warning Signage MUST be displayed to mark Ear Protection Zone	☐
Hearing surveillance must be carried out	☐

--