

-----Original Message-----

From: NCC - Tree Team <Tree.Team@newport.gov.uk>

Sent: 29 January 2026 09:06

To: NCC - Planning <Planning@newport.gov.uk>

Subject: RE: Planning Consultation Request for case ref: 25/0608

Hello,

Additional information is required

1) regarding the impact on the trees is required i.e. what is the foundation or is it sat on the ground. Sitting on the ground would not be acceptable due to the impact on gaseous exchange. The instillation of the foundation within the root plate also needs due consideration such as hand dig etc. this needs to be demonstrated.

2) Access pruning to lift the container into place also needs to be considered and how they will undertake this needs to be submitted. Due to the proximity of the trees canopy they are likely to be impacted.

Cofion Cynnes / Kind Regards,

Richard Baron

Swyddog Coeddyddiaeth / Arboricultural Officer Cefn gwlad a Chadwraeth/ Countryside & Conservation Gwasanaethau'r Ddinas / City Services Cyngor Dinas Casnewydd / Newport City Council