

Tree Technical Note

Client: Mr B Attewell

Site Address: Ivydene, Court Farm, Whitson, Newport. NP18 2AY


Note by: James Pinder Tech Cert (Arbor A)

Date: 18.07.25

Findings & outcome

- Thuja plicata garden hedge to the North of the proposed access.
- Mixed native species field hedge to the South of the proposed access.
- A hard pruned plum tree with grazing animal cambium damage is next to the metal supports in the orchard area. It is the most northern located tree on the site plan. This tree will potentially stay (and can do without risk of harm) but it is likely to suffer stem breakage and removal in the future.
- No trees are in close proximity to the proposed work.
- Site plan has been amended to now show proximity of Tree Protection Fences to the proposed work area.

There is approximately 8m from closest tree stem to the access flare. This is an ample distance in order to demonstrate site separation from the project to retained trees. The proposed site plan has now been amended and is shown below. Red Tree Protection Plan lines have been added to show the location of temporary tree protection fencing while the work is carried out. There is therefore no risk to retained trees by the proposed access creation work other than the obvious loss of a small section of roadside verge hedge.



Site Photos



Plum tree with grazing damage and hard pruning.



Yellow lines show approximate access.

