

Application Description:

Installation of Air Source Heat Pump

Planning reference number:

26/0126

I refer to the above application passed to the Environmental Protection Team for comment.

I object to the proposed installation of the Air Heat Source Pump because it has exceeded the permissible threshold and could attract statutory noise complaints. Therefore it is non-compliant. The applicant should be advised to consider other appropriate noise mitigation measures to address the impact of the noise.

The A-weighted sound pressure level used in the noise level calculation is not from the provided manufacturer's data sheet. Advise the applicant to use the A weighted sound pressure level from the manufacturer's data sheet.