

Newport City Council
Civic Centre
Newport
NP20 4UR

Date: 27th August 2026

Our Ref: 1002152

Your Ref: 26/0593

Grid Ref: 339114,188102

Site: Castle Farm Bishton Road Bishton, Newport, Newport, NP18 2DZ

Development: PRIOR NOTIFICATION FOR STEEL PORTAL FRAME EXTENSIONS TO THE NORTH AND SOUTH OF EXISTING AGRICULTURAL BUILDING

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We would request that if you are minded to grant Planning Consent for the above development that the **Conditions** and **Advisory Notes** listed below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

Conditions

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Advisory Notes

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com. Please quote our reference number in all communications and correspondence.

Yours sincerely,

Developer Services

Dŵr Cymru Welsh Water