

-----Original Message-----

From: Kimberley, John (Structural Engineer) <John.Kimberley@newport.gov.uk>

Sent: 24 October 2025 12:17

To: NCC - Planning <Planning@newport.gov.uk>

Subject: RE: Planning Consultation Request for case ref: 25/0540

There are no detailed design drawings or calculations for the retaining walls submitted with the application. This application cannot be approved structurally until the design and calcs are submitted.

Regards

John