

**From:** Liam Griffiths <LiamG@asbriplanning.co.uk>

**Sent:** 11 January 2021 11:31

**To:** Burrows, Lydia (Planning Officer) <Lydia.Burrows@newport.gov.uk>

**Subject:** RE: PP-09075588 Land To South Of Glan Usk Primary School Herbert Road Newport South Wales

Hi Lydia,

Further to the below please see documents attached. I've also had the following from Engie. Please could this email and the attachments be sent across to Steve?

**Engie comments**

No certificate has been issued from NHBC for signing off the Gas membrane activity as it wasn't required under any of their conditions on the portal. The category of gas protection didn't require this level of scrutiny due to its category '**gas characteristic situation 2**'. The membrane was installed as per manufacturers recommendations with NHBC and Building control inspectors visiting during the period as a staged sign off as we progressed the build.

We had **NHBC CML** and **Building control certification** on completion of the scheme both attached.

Kind regards,

**Liam Griffiths – Planner**

**Asbri Planning Ltd | T: 02920 732652 | W: <http://www.asbriplanning.co.uk>**