

25/0873

60 Bassaleg Road

Newport

NP20 3PY

There are no detailed design drawings or calculations for the retaining walls submitted with the application. This application cannot be approved structurally until the design and calcs are submitted.

Regards

John