

-----Original Message-----

From: Kimberley, John (Structural Engineer) <John.Kimberley@newport.gov.uk>

Sent: 08 May 2026 15:02

To: NCC - Planning <Planning@newport.gov.uk>

Subject: RE: Planning Consultation Request for case ref: 26/0217

Hello Planning

The retaining wall design and foundations are suitable to support the highway and surrounding land. The piling type has not been discussed but the recommendation is that it shall be rotational piling and not percussive due to the locality of nearby residential properties that may be affected by noise and vibration if percussive piling techniques are utilised.

Regards

Structures Team