

Highway Response

Ref: RECON 26/0182

Date: 15/05/26

PROPOSAL: ADDITION OF A PORCH AND NEW DRIVEWAY

SITE: 1 Hornbeam Walk Bassaleg Newport NP10 8PW

Case Officer: Jonathan Jones

Highway Officer: Kevin Jackson

Highway recommendation:

Objection.

Highway Comments:

The proposal includes an inappropriately sized and located dropped kerb arrangement. The details of the boundary treatment would fail to define the drive or confine vehicular movements and would obstruct the visibility to one side. This is in addition to approaching the footway at an angle that prevents proper observation.

The footway crossing is not appropriately sized or orientated. There may be scope for some relaxation of standards due to the footway not being continuous and the site being constrained. However, the current proposals are not acceptable.