

From: Kimberley, John (Structural Engineer) <John.Kimberley@newport.gov.uk>

Sent: 27 May 2026 15:07

To: NCC - Planning <Planning@newport.gov.uk>

Subject: RE: Planning Consultation Request for case ref: 26/0384

Hi Geraint

Whilst I have no objection structurally, it might be good to see the designer's specification for the retaining wall. The drawing shows no drainage behind the wall, no filtration material and is not waterproofed. Is internal steel reinforcement being used to prevent the wall from sliding/overturning at foundation level?

Regards

John