

Newport County Council  
Civic Centre  
NEWPORT  
NP20 4UR

**Date: 28/10/2025**  
**Our Ref: PLA0090567**  
**Your Ref: 25/0792**

Dear Sir/Madam,

**Grid Ref: ST277870 327835 187057**  
**Site: Bridge Over Ebbw River, Forge Mews, Newport**  
**Development: DEMOLITION OF THE OLD BASSALEG BRIDGE**

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We would request that if you are minded to grant Planning Consent for the above development that the **Conditions and Advisory Notes** provided below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

### **Asset Protection**

The proposed development site is crossed by a 225mm public combined sewer, 100mm foul rising main, 1200mm combined sewer. Please see copy of indicative public sewer record attached. No operational development is to take place or SuDS features installed within 3 metres either side of the centreline of the 225mm sewer, 3.6m either side of the 100mm rising main and 6m either side of the 1200mm sewer. We request that prior to commencing any operational development the location of this asset is determined. It may be possible for the assets to be diverted under Section 185 of the Water Industry Act 1991, the cost of which will be re-charged to the developer.

In addition the site is crossed by a trunk/distribution watermain, the approximate position being shown on the attached plan. Dwr Cymru Welsh Water as Statutory Undertaker has statutory powers to access our apparatus at all times. I enclose our Conditions for Development near Watermains. It may be possible for this watermain to be diverted under Section 185 of the Water Industry Act 1991, the cost of which will be re-charged to the developer. The developer must consult Dwr Cymru Welsh Water before any development commences on site. It seems the proposed development will be within the protection zones of these assets, we therefore request that if you are minded to grant Planning Consent for the above development that the **Conditions and Advisory Notes** listed below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

### **Conditions**

The development hereby permitted shall not be commenced until details of a construction design method statement and risk assessment for the protection of the structural condition of the public water main and sewer assets crossing the site has been submitted to and approved in writing by the local planning authority. No other development pursuant to this permission shall be carried out until the approved protection measures have been implemented and completed. Thereafter, the protection measures shall be retained at all times during the lifetime of this permission.

**Reason:** To protect the integrity of the public watermain(s) and sewer(s) and avoid damage thereto.

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network.

**Reason:** To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

### **Advisory Notes**

*The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of [www.dwrcymru.com](http://www.dwrcymru.com)*



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.

*The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.*

*In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.*

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at [developer.services@dwrcymru.com](mailto:developer.services@dwrcymru.com)

Please quote our reference number in all communications and correspondence.

Yours faithfully,

**Phillip Little**  
**Development Planning Officer**  
**Developer Services**



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.