

From: Rose, Jak (Environmental Health Officer) <Jak.Rose@newport.gov.uk>
Sent: 11 September 2026 15:42
To: Quinn, Vicky (Senior Planning Officer) <Vicky.Quinn@newport.gov.uk>
Cc: Mwanza, Chama (Environmental Health Officer)
<Chama.Mwanza@newport.gov.uk>
Subject: Planning ref 26/0570 EH response

Hi Vicky,

I have reviewed the above, insufficient technical information has been provided in relation to the proposed spray booth installation and operation.

In the absence of detailed specifications and supporting technical documentation, including (but not limited to) details of extraction systems, filtration arrangements, stack height, emission controls, noise levels and predicted environmental impacts, Environmental Health is unable to fully assess the potential effects of the development on neighbouring receptors or provide a substantive consultation response.

Accordingly, we request that the necessary technical information is submitted by the applicant and recommends that the application is not determined until this information has been provided and assessed.

Cofion/Regards

Jak Rose

Environmental Health Officer/ Swyddog Iechyd yr Amgylchedd

Environment & Public Protection/ Amgylchedd a Diogelu'r Cyhoedd

Newport City Council / Cyngor Dinas Casnewydd

t) +44 01633 832905

jak.rose@newport.gov.uk

