

Newport County Council
Civic Centre
NEWPORT
NP20 4UR

Date: 19/12/2025
Our Ref: PLA0092011
Your Ref: 25/0994

Dear Sir/Madam,

Grid Ref: ST266902 326667 190208
Site: Golynos Cottage, Mountain Road, Newport
Development: REPLACEMENT DWELLING

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

Firstly, with respect to the submitted application form and accompanying 'Proposed Site Plan', we acknowledge that the development proposes to discharge foul and surface water flows to a septic tank and soakaway respectively.

Since the proposal intends utilising an alternative to mains drainage for foul water, we would advise that the applicant seek advice from Natural Resources Wales and/or the Building Regulations Authority as the regulatory body for this method of drainage. Should circumstances change and a connection to the public sewerage system is preferred, we must be re-consulted on this application.

Turning to surface water drainage, as of 7th January 2019, this proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. In the event this proposed development amounts to a total impermeable area of 100sqm or more, approval of Sustainable Drainage Systems (SuDS) features will be required in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. In this instance, we offer no objection to proposals for disposal of surface water flows into a soakaway, in principle, subject to consultation and agreement with the regulatory body or riparian owner of this system.

Accordingly, if you are minded to grant planning consent for the above development, we would request that the following **Condition and Advisory Notes** are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets:

Condition

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment

Advisory Notes

As of 7th January 2019, this proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. In the event this proposed development amounts to a total impermeable area of 100sqm or more, approval of Sustainable Drainage Systems (SuDS) features will be required in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. It would therefore be recommended that the developer engage in consultation with Newport County Council, as the determining SuDS Approval Body (SAB), in relation to their proposals for SuDS features. Please note, Dwr Cymru Welsh Water is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation.

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

In accordance with Planning Policy Wales (Edition 11) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dwr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwr-cymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Phillip Little
Development Planning Officer
Developer Services