



## HS37: Simple construction phase plan

|                                                                              |                                                                                                             |
|------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------|
| Your name/company                                                            | Kevin Dorrington, K W Dorrington<br>116 Aberthaw Circle<br>Newport<br>NP19 9QJ                              |
| Client                                                                       | Dldar Ahmed, Newport Hand Car Wash<br>Somerton Park Garage<br>Cromwell Rd<br>Newport<br>Newport<br>NP19 0HT |
| Architect/principal designer                                                 |                                                                                                             |
| What is the job?<br>Is there anything that the client has made you aware of? |                                                                                                             |
| Key dates                                                                    | Start: 01 December 2025<br>Finish: 05 December 2025                                                         |
| Where are the toilets, washing & rest facilities?                            |                                                                                                             |
| Is there anything the client has made you aware of?                          |                                                                                                             |
| Who else is on site                                                          |                                                                                                             |
| Principal contractor                                                         | K W Plant<br>32 Mill Court<br>Hafodyrynys<br>Crumlin<br>Caerphilly<br>NP11 5DS                              |
| How will you keep everyone on site updated during the job?                   |                                                                                                             |

| What are the main dangers on site?                                                                                                                                                                                                                 | Hazard is present | What controls do you have? |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|----------------------------|
| Falls from height<br>- Make sure ladders are in good condition, at the correct angle and secured<br>- Prevent people and materials falling from roofs, gable ends, working platforms and other open edges using guardrails, midrails and toeboards |                   |                            |
| Collapse of excavations<br>- Shore excavations; either cover or barrier excavations to stop people and plant falling in                                                                                                                            |                   |                            |
| Collapse of structures<br>- Support structures (such as walls, beams, chimney breasts and roofs) with props; ensure props are installed by a competent person                                                                                      |                   |                            |
| Exposure to building dusts                                                                                                                                                                                                                         |                   |                            |

|                                                                                                                                                                                                                    |  |  |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| - Prevent dust by using wet cutting and vacuum extraction on tools; use a vacuum cleaner rather than sweeping; use a suitable, well-fitting mask                                                                   |  |  |
| Exposure to asbestos<br>- If you suspect that asbestos might be present, don't start work until a demolition/refurbishment survey has been carried out<br>- Make sure everyone on the site is aware of the results |  |  |
| Activities or workers requiring supervision<br>- Who will be supervising?                                                                                                                                          |  |  |
| Electricity<br>- Turn electricity supply and other services off before drilling into walls<br>- Do not use excavators or power tools near suspected buried services                                                |  |  |
| Risks to members of the public, the client and others<br>- Keep the site secure to prevent unauthorised access; net scaffolds, use rubbish chutes                                                                  |  |  |
| Other dangers on site                                                                                                                                                                                              |  |  |

Following the guidance is not compulsory, unless specifically stated, and you are free to take other action. If you are unsure about how you can make your site safer, see [www.hse.gov.uk/construction](http://www.hse.gov.uk/construction)

This template document has been developed based on the HSE CIS80 under © Crown copyright