

Newport County Council
Civic Centre
Newport
NP20 4UR

Date: 04/09/2025
Our Ref: PLA0089564
Your Ref: 25/0375

Dear Sir/Madam,

Grid Ref: ST308868 330923 186933

Site: Land Formerly Known As Whitehead Works, Mendalgief Road, Newport

Development: Erection Of A 66no. Bedroom Care Home (Use Class C2) For Older People With Associated Access, Parking, Landscaping And Ancillary Buildings

In respect of the aforementioned planning application, we can confirm that Dwr Cymru Welsh Water have been previously informed of the proposed development and consulted, as a 'Specialist Consultee', in accordance with Schedule 1C Article 2D of the Town & Country Planning (Development Management Procedure) (Wales) (Amendment) Order 2016. We note that our consultation response (Ref: PPA0009508) has been acknowledged and included at Appendix 7 of the accompanying Pre-Application Consultation (PAC) Report, prepared by LNT Care Developments.

Firstly, following works on site we confirm the watermain previously mentioned within the site boundary has been isolated and therefore the proposed site layout no longer has impact to our assets and its protection zone. We therefore remove our holding objection and provide the below comments:

with respect to the submitted application form and accompanying 'Surface Water Drainage Strategy' and 'Foul Water Drainage Strategy' (Drawing No. 6375-JPG-ZZ-ZZ-DR-D-1400 & 1401), we acknowledge that the development proposes to discharge foul and surface water flows to a private surface water sewer respectively. The proposed development site is located in the catchment of a public sewerage system which drains to Nash Wastewater Treatment Works (WwTW). We have considered the impact of foul flows generated by the proposed development and concluded that flows can be accommodated within the public sewerage system.

Turning to surface water drainage, as of 7th January 2019, this proposed development is subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore requires approval of Sustainable Drainage Systems (SuDS) features, in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. In this instance, we offer no objection to proposals for disposal of surface water flows into a private surface water sewer, in principle, subject to consultation and agreement with the regulatory body or riparian owner of this system.

In addition, the water supply system in the immediate vicinity has insufficient capacity to serve the development and will also cause detriment to existing customers' water supply. A hydraulic modelling assessment is required to establish the scope of any reinforcement works to be completed in advance of making the connection and can be secured by a suitably worded planning condition.

Notwithstanding this, we would request that if you are minded to grant Planning Consent for the above development that the **Conditions** and **Advisory Notes** listed below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

Conditions

No buildings on the application site shall be brought into beneficial use until such time as reinforcement works to the local water supply network, at which the development shall connect, have been completed as identified in a Hydraulic Modelling Assessment and written confirmation of this has been issued to the Local Planning Authority.

Reason: To ensure the site is served by a suitable potable water supply.

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Phillip Little
Development Planning Officer
Developer Services



Welsh Water is owned by Glas Cymru – a ‘not-for-profit’ company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni ‘nid-er-elw’.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.