

Aldous, Catherine (Senior Planning Officer)

From: Arnall, Guy
Sent: 10 July 2025 11:02
To: Aldous, Catherine (Senior Planning Officer)
Subject: Planning Consultation Request for case ref: 25/0391 (Civic Centre Godfrey Road Newport South Wales NP20 4UR)

Hi Catherine

Re: 25/0391- PARTIAL DISCHARGE OF CONDITION 5 (DETAILS OF HIGH ROPES AND BOSUN CHAIR FIXINGS) OF 24/0897 PROPOSALS TO REPAIR AND CLEAN NEWPORT CIVIC TOWER, INCLUDING PIECEMEAL RE POINTING WORKS, RE AFFIXING OF 2NO. DISPLACED STONE PANELS IN CORRECT ALIGNMENT; REMOVAL OF LOOSE/DETACHING STONE AND MORTAR REPAIRS; LOCALISED REPAIRS TO FRACTURED AND SPALLED STONE PANELS AND CLEANING OF MASONRY VIA FACADE GOMMAGE.

This partial DOC proposes that a temporary cradle supported by 2 jibs will be used to provide external access, to enable external masonry repointing of the clock tower.

Calculations for structural adequacy have been undertaken and provided for the top floor of the Clock tower.

Load-spreading timber blocks are to be installed upon the existing window ledge, which will also provide the necessary protection for the masonry from load damage.

Timber scaffold boards are also proposed upon the floor beneath the temporary structure, to spread the load. These, again, will provide suitable protection of the historic fabric.

Upon this basis, I am happy that you discharge.

Kind regards,

Guy Arnall

Prif Swyddog Treftadaeth / Principal Heritage Officer
Swyddog Dirprwyedig (Adeiladau Rhestredig) / Delegated Officer (Listed Buildings)

Adfywio a Datblygu Economaidd / Regeneration and Economic Development
Cyngor Dinas Casnewydd / Newport City Council

E: Guy.Arnall@newport.gov.uk | Planning@newport.gov.uk