

Highway Response

Ref: 25/0279

Date: 23/04/24

PROPOSAL: PRIOR NOTIFICATION FOR DEMOLITION OF SINGLE STOREY TEMPORARY TIMBER FRAMED BUILDING

SITE: Brynglas House Brynglas Road Newport South Wales NP20 5QU

Case Officer: Francesca Sanders

Highway Officer: Kevin Jackson

Highway recommendation:

Prior approval required.

Highway Comments:

The method statement makes reference to cutting an access using plant and machinery. In addition, there is reference to numbers of vehicles waiting and loading, without information on their management, location or number.

Further detail is needed to ensure that the public are protected and any closures or other procedures put in place. We would therefore recommend that prior approval is required to address these issues.