

From: Manning, Steve (Senior Scientific Officer) <Steve.Manning@newport.gov.uk>

Sent: 22 October 2025 15:21

To: Wescott, Thomas (Senior Scientific Officer)

<Thomas.Wescott@newport.gov.uk>

Cc: Hawkins, Grant (Senior Planning Officer) <Grant.Hawkins@newport.gov.uk>

Subject: RE: Planning Consultation Request for case ref: 25/0767

Afternoon Tom and Grant

I have looked at the submitted specifications and provided they are implemented in the final build they should satisfy a CS2 level of protection subject to membranes and details being verified through integrity testing.

Cofion gorau / Kind regards,

Steve

Steve Manning MSc CEnvH MCIEH

Senior Scientific Officer

Amgylchedd a Diogelu'r Cyhoedd / Environmental Protection Team

Cyngor Dinas Casnewydd / Newport City Council

Civic Centre

Godfrey Road

Newport NP20 4UR

Tel 01633839908

steve.manning@newport.gov.uk