

Main Location: 10 Summerhill Avenue
Newport
South Wales
NP19 8FP

Application Description: INSTALLATION OF AIR SOURCE HEAT PUMP

Planning reference number: 25/0670

Planning case officer: Ben Webster

Environmental Health Consultation Response (FINAL)

Updated comments;

I refer to the above application passed to the Environmental Protection Team for comment.

I confirm I have no objections to the proposals; however the following condition should be attached to any permission granted;

Air Source Heat Pump – Maintenance

The installed equipment shall be regularly maintained in order to ensure its continued satisfactory operation in accordance with the manufactures recommended service intervals. In the absence of such intervals; the equipment shall be maintained annually.

Reason: To ensure that the amenities of occupiers of other premises in the vicinity are protected.

Air Source Heat Pump – Installation

The equipment shall be installed on a robust level and solid surface with sufficient loading bearing capacity.

Reason: To ensure that the amenities of occupiers of other premises in the vicinity are protected.

Acoustic fencing

Boundary fencing should be of a solid construction of a minimum surface density of 10kg/m², a minimum height of 1800mm and of close boarded timber construction. The fencing shall thereafter be maintained in accordance with the approved details.

Reason: To ensure that the amenities of occupiers of other premises in the vicinity are protected.