

From: Mwanza, Chama (Environmental Health Officer)

<Chama.Mwanza@newport.gov.uk>

Sent: 13 January 2026 17:16

To: Hawkins, Grant (Principal Planning Officer) <Grant.Hawkins@newport.gov.uk>

Subject: RE/1071

Hi Grant,

Please find my comments on 25/1071 below.

Date:

13.01.2026

Main Location:

Land Adjacent To Electric Substation

Celtic Way

Celtic Lakes

Newport

South Wales

Application Description:

INSTALLATION OF AN UNDERGROUND CABLE CONNECTION

FROM 132KV SUBSTATION TO A DATA CENTRE

Planning reference number:

25/1071

Planning case officer:

Grant Hawkins

I refer to the above application passed to the Environmental Protection Team for comment.

I have no objection to the proposed installation of an underground cable connection; however the following condition should be attached to any permission granted;

Plant and Equipment Noise.

Noise emitted from plant and equipment located at the site shall be controlled such that the rating level, calculated in accordance with BS4142:2014, does not exceed a level of 5dB below the existing background level, with no tonal.

Officer name:

Chama Mwanza

Officer Email:

Chama.Mwanza@newport.gov.uk

Officer Contact number:

01633 839905

SRT Number:

25/14243/ABRPFA