

Document number: I25003598

1/1

Inspection certificate 3.1 as per DIN EN 10204

Purchaser : PROTEGO UK Ltd.
Purchaser Order No. : PUK12305
Reference : PO: PO250211783
Order Acknowledgement No. : 025105045 Pos.: 10

Serial number : 025105045-0010-001

Description

Free vent - end-of-line deflagration flame arrester
 PROTEGO® LH/AD-80-IIC-X3

Remark

TAG-No.: FA-2000

Certificate : IBExU06ATEX2109X

Flange 1 : EN 1092-1 DN80 PN16

Raw Material / Material

housing module
 housing: 1.4408
 weather hood: stainless steel
 protective screen: stainless steel
 bolts/nuts: A4
 gasket: PTFE

PROTEGO® flame arrester unit
 FLAMEFILTER® cage: 316 SS/1.4571
 FLAMEFILTER®: 1.4571
 bolt: A4

No objections, stated values are within the allowable tolerances.

Test	Details
Visual check	Passed
Dimensional check	Passed
Width of gap	0,2 mm

Braunschweig 10-02-2025
Place Date

Braunschweig
Place Date

i. V. Schlüter

Authorized inspection representative

Authorized inspection representative of customer

This document was issued electronically and is valid without signature.