

SHEET NOTES

ALL VERTICAL DIMENSIONS ARE RELATIVE TO ASSOCIATED BUILDING SLAB LEVEL.

DO NOT SCALE FROM DRAWINGS.
ALL DISCREPANCIES TO BE REPORTED TO GENSLER
ARCHITECTS IMMEDIATELY. ALL DIMENSIONS TO BE
VERIFIED BY CONTRACTOR ON SITE PRIOR TO ANY
WORKS.

Description	approximate length
PALLADIN V-GUARD	397.2
Stronguard RCS PAS 68	644.7
Stronguard standard	1,251.6
Stronguard standard	115.2

**FOR ALL IMPACT RATED FENCES,
BARRIERS AND GATES**

MINIMUM IMPACT RATING STANDARD
PAS 68:2010 V/7500(N2)/48/90:2.4/7.9

EXTERIOR PADLOCKS SHALL BE FITTED WITH ANTI-DUST AND ANTI-MOISTURE PROTECTIVE COVER ASSEMBLIES. WHEN A PADLOCK IS SPECIFIED FOR DOOR HARDWARE SUITABLE HASP AND STAPLE FITTINGS MUST BE INSTALLED ON THE DOOR. ALL LOCKS TO BE SUITED.

LEGEND

- | | |
|---|---|
|  | SITE BOUNDARY |
|  | EXT-402 SECURITY FENCE
STRONGGUARD SR2 2.4m |
|  | EXT-401 SECURITY FENCE STRONGGUARD
PAS 68 RCS 25 2.4m |
|  | EXT-403 SECURITY FENCE PALLADIN
V-GUARD 2.4m |
|  | EXT-405 CANTILEVER GATE
(FILL MATCHING ADJOINING FENCE) |
|  | EXT-404 SECURITY SLATED CANTILEVER
GATE (FILL MATCHING ADJACENT FENCE) |
|  | EXT-406 AUTOMATIC RISING ARM BARRIER
EAGLE ARRESTOR (PAS68 RATED) |
|  | EXT-407 MANUAL RISING ARM BARRIER
PAS 68 |
|  | EXT-408 SECURITY TURNSTILE
DORMA KABA FTS-M03 (WITH ROOF DZ) |
|  | EXT-301 ARMCO CRASH BARRIER (REFER
TO ENGINEER'S DETAIL & SPECIFICATION) |
|  | EXT-409 SWING GATE, CLEAR OPENING
UNANNOTATED
(HEIGHT, FILL AND CRASH RATINGS
MATCHING ADJOINING FENCE)
EXT-40411 PERSONNEL SWING GATE,
CLEAR OPENING 1.2m, (HEIGHT, FILL AND
RATING MATCHING ADJOINING FENCE)
BLANNING PANEL REQUIRED |
|  | EXT-401 110mm S&S GUARDING TO
POND/S&S/DRAIVE- POST CENTALS
& FOUNDATIONS TO SET DETAILS |

NOTES:
1. FOR SITE WIDE LEVELS AND DRAINAGE REFER TO CIVIL ENGINEER'S DRAWINGS.
2. FOR WHITE LINING REFER TO CIVIL ENGINEER'S INFORMATION & DRAWINGS.

As indicated@A0



Gensler

4 St Philip's Place
First Floor
Birmingham
B3 2SL
United Kingdom

Tel. +44 (0)121 260 1600



CWL01-02

Duffryn Lane Newport
NP10 8BE

Design Team

Design	GENSLER
Drawn	SD
Checked	JL
Date	24.10.25
Company Project No.	P-020340
M.S. Project No.	P-020340


Approvals

CUSTOMER		MICROSOFT	Date
Microsoft Design Manager	LEVI HOLLAND ALAN MARENZE		
Microsoft Electrical Engineer	MARK CLEWSON		
Microsoft Test/Type Engineer	GERNARD CLUNAN		
Microsoft Mechanical Engineer	ANDY LASTER		
USA	PATRICK DOHERTY/ALAN ROWAN/ PROSPERITY MARLEY		
Telecom	JOUL PARAWANIE / MARK KELLY		
Security Manager	DAVID BEADLE		
Environmental	DEREDRE GORMAN		
PROJECT MANAGEMENT			
Project Planner			
Project Manager			Date
Senior Project Manager			
Development Manager			
Project Manager			
Quality Control Reviewer			
Quality Control FYAE			

Revisions

[illegible]

Registration



SITE NORTH

Bar Code

Sheet Title/Number

SITE - FENCING PLAN

CWL01-02-
L-B-02-0

CWL01-02 L-8-02-0-E