

From: Clodagh Macken <clodagh.macken@carneysweeney.co.uk>

Sent: 16 September 2025 16:12

To: Davidson, Joanne (East Area Development Manager)

<Joanne.Davidson@newport.gov.uk>

Subject: 25/0488 and 25/0592 - Uskmouth S73 applications

Hi Joanne,

Please find below the additional information requested to address the responses from DCWW and Landscape officer, relating to application refs 25/0488 and 25/0592:

DCWW

The fire water tanks each have a net capacity of 338 m3 and the replenishment rate is 822 l/min (13.7 l/s) at 1Bar.

Landscape Officer

Further clarification is sought regarding the impact of the proposed changes on the approved soft landscaping scheme.

In this regard, the proposed fire tanks are located within the approved battery compound, which comprises the aggregate stone plateau. No landscaping is located on this part of the site, so this element of the proposal has no impact on the approved landscape scheme.

The amendment to the balancing pond involves a slight shift to the position of the pond's northern boundary to avoid the pylon exclusion zone. However, the bund surrounding the balancing pond will still be landscaped in accordance with the approved details.

Likewise, a small amendment is proposed to the position of the BESS plateau boundary, however the bund forming the perimeter of the plateau will still be planted and landscaped as approved.

In relation to application ref: 25/0488 only, the proposed amended cable route does not travel through any land proposed for landscaping.

Overall, it is confirmed that the proposed amendments have no impact upon the approved soft landscaping proposals.