

Newport County Council
Civic Centre
NEWPORT
NP20 4UR

Date: 21/04/2026
Our Ref: PLA0094497
Your Ref: 26/0207

Dear Sir/Madam,

Grid Ref: ST299861 329957 186181

Site: 26 Buxton Close, Newport

Development: OUTLINE APPLICATION (WITH ALL MATTERS RESERVED FOR SUBSEQUENT APPROVAL EXCEPT FOR ACCESS) FOR THE DEVELOPMENT OF 1 NO. DWELLING AND ASSOCIATED PARKING

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

This site is crossed by two public sewers with their approximate positions being marked on the attached statutory public sewer record. In accordance with the Water Industry Act 1991, Dwr Cymru Welsh Water requires access to its apparatus at all times in order to carry out maintenance and repairs. Having regard to the Proposed Site Plan Layout 1,2,3 and Layouts All, it appears the proposed development would be situated within the protection zone of the public assets measured 3 metres either side of the centreline. Please note, the distance specified for this protection zone is indicative and based on industry standard guidelines. However, the depth of the asset will need to be verified on site which may infer a greater protection zone. For completeness, we recommend the developer refer to their title deeds to confirm if there are any covenants or restrictions associated with the assets crossing the proposed development site.

In this instance, it appears there is sufficient space and scope to re-position the development outside the protection zone of the asset. Therefore, it is strongly recommended that the drawings reference Proposed Site Plan Layout 1,2,3 and Layouts All are amended to take into account the location of the assets crossing the site and we respectfully request we are re-consulted on receipt of this information. It is also recommended that the developer contact our Plan and Protect team (PlanandProtect@dwrcymru.com) to carry out a survey to verify the location of the assets and establish their relationship to the proposed development.

Accordingly, for the reasons outlined above, we offer a **Holding Objection** until such time as additional/amended information has been submitted and request we are re-consulted on receipt of this information.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Phillip Little
Development Planning Officer
Developer Services



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.