

Highway Response

Ref: 26/0591

Date: 11/08/26

PROPOSAL: PARTIAL DISCHARGE OF CONDITION 4 (DEMOLITION AND CONSTRUCTION METHOD STATEMENT) OF 25/0328 PROPOSED ENGINEERING WORKS FOR THE REPAIR AND REINSTATEMENT OF THE COLLAPSED BANK OF THE RIVER EBBW

SITE: Land Adjacent To 7 Ebbw Close Rogerstone Newport South Wales

Case Officer: Adam Foote

Highway Officer: Kevin Jackson

Highway recommendation:

Recommend partial discharge in so far as the CEMP is approved but remains to be adhered to.

Highway Comments:

The Amended CEMP now ensures all offloading is within the site and provides for banksmen to ensure safe manoeuvres adjacent to the site access. Some reversing of HGVs is necessary on highway but will be supervised and avoid school/peak travel times.

Suitable pedestrian diversions have been identified and will be in place. Appropriate arrangements for wheel washing etc are identified and will be in place.

Parking will be monitored and sanctions in place for inconsiderate or unlawful staff parking.

In summary, the CEMP adequately addresses the concerns of Highways Officers.