

From: Baron, Richard (Arboricultural Officer) <Richard.Baron@newport.gov.uk>
Sent: 02 February 2026 10:46
To: Hawkins, Grant (Principal Planning Officer) <Grant.Hawkins@newport.gov.uk>
Subject: RE: 25/1071

Hi Grant,

Sorry on the delay,

Looking at the supplied information the route is situated within the pre existing hard standing the trench will therefore will have minimal impact on the trees.

Conditions are:

The spoil must be situated on the existing hard standing to prevent compaction to the soil.

When operating machinery within 5m of trees excavators that could strike the trees when turning must be appropriately supervised with banksmen.

Any damage to trees must be reported to the NCC Tree Team and suitable works to mitigate any harm rectified at the developers cost.

Cofion Cynnes / Kind Regards,

Richard Baron

Swyddog Coedyddiaeth / Arboricultural Officer

Cefn gwlad a Chadwraeth/ Countryside & Conservation

Gwasanaethau'r Ddinas / City Services

Cyngor Dinas Casnewydd / Newport City Council

Rhif ffôn / Phone number: 07583 140076