

Highway Response

Ref: 26/0119

Date: 27/04/26

PROPOSAL: CREATION OF RAISED PARKING SPACES TO THE FRONT OF THE PROPERTY ALONG WITH DROPPED KERB ACCESS

SITE: 1 Oakfield Gardens Newport NP20 4NJ

Case Officer: Marnie Ostler

Highway Officer: Kevin Jackson

Highway recommendation:

Objection on highway safety grounds.

Highway Comments:

The plans show two parking spaces both are unacceptable and the access is too close to the corner.

The perpendicular space would have to be 5.5m deep to be acceptable and this doesn't appear to be possible. The second is not acceptable as it meets highway at an acute angle making appropriate observations impossible and therefore its use unsafe.