

From: Mwanza, Chama (Environmental Health Officer)
Sent: Wednesday, January 28, 2026 15:01
To: Burrows, Lydia (Planning Officer) <Lydia.Burrows@newport.gov.uk>
Subject: RE; 25/0897

Hi Lydia,

Please find my comments on 25/0897 below:

Date: 28.01.2026

Main Location:

Public Convenience Caerleon road NP19 7FX

Application Description:

Change of Use of Disused Public Convenience to Cafe, front facade extension and associated external alterations

Planning reference number: 25/0897

Planning case officer:

Lydia Burrows

I refer to the above application passed to the Environmental Protection Team for comment.

I have no objections to the proposal; Due to the potential of noise, fumes, dust concerns that may arise from the proposed that may trigger statutory nuisance complaints from some residents living closer to the site, I recommend the following conditions should be attached to any permission granted;

Fume Extraction

Fumes from the food preparation areas shall be mechanically extracted and the extraction system shall be provided with de-greasing and de-odorising filters. Details of the extraction equipment (including scaled schematics, location plans, odour attenuation measures and future maintenance) shall be submitted to and approved in writing by the Local Planning Authority prior to its installation, and the equipment shall be installed in accordance with the approved details prior to the commencement of use for the cooking of food.

Reason: To ensure that the amenities of occupiers of other premises in the vicinity are protected and in the interests of visual amenities.

Plant and Equipment Noise.

Noise emitted from plant and equipment located at the site shall be controlled such that the rating level, calculated in accordance with BS4142:2014, does not exceed a level of 5dB below the existing background level, with no tonal.

Reason: To ensure that the amenities of occupiers of other premises in the vicinity are protected.

Construction Environmental Management Plan

No development shall take place until a site specific Demolition and Construction Environmental Management Plan has been submitted to and been approved in writing by the Council. The plan must demonstrate the adoption and use of the best practicable means to reduce the effects of noise, vibration, dust and site lighting. The plan should include, but not be limited to:

- Procedures for maintaining good public relations including complaint management, public consultation and liaison
- Arrangements for liaison with the Newport City Council Noise & Neighbourhood Team
- Deliveries to and removal of plant, equipment, machinery and waste from the site must only take place within permitted hours
- Mitigation measures as defined in BS 5228: Parts 1 and 2 : 2009 Noise and Vibration Control on Construction and Open Sites shall be used to minimise noise disturbance from construction works.
- Procedures for emergency deviation of the agreed working hours.
- Measures for controlling the use of site lighting whether required for safe working or for security purposes.

- Measures to mitigate demolition dust and material causing a nuisance to local residents, for example sheeting of loads and wheel washing apparatus

Reason: To protect the amenities of occupiers of other premises in the vicinity

Officer name:

Chama Mwanza

SRT Number:

26/00942/ABRPFU

Cofion gorau / Kind regards,

Chama Mwanza MCIEH

Swyddog Iechyd yr Amgylchedd / Environmental Health Officer

Tîm Diogelu'r Amgylchedd / Environmental Protection Team

Gwarchod y Gymuned / Community Protection

Amgylchedd a Diogelu'r Cyhoedd/ Environment & Public Protection

Cyngor Dinas Casnewydd / Newport City Council