

Newport County Council
Civic Centre
NEWPORT
NP20 4UR

Date: 28/04/2025
Our Ref: PLA0086845
Your Ref: 25/0262

Dear Sir/Madam,

Grid Ref: ST304916 330496 191724

Site: Land To The Rear Of 29, Robertson Way, Newport

Development: SUB-DIVERSION OF PLOT TO CREATE A 2 STOREY 3NO. BEDROOM DWELLING TO REAR AND ASSOCIATED ENGINEERING

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

The proposed development site is located in the catchment of a public sewerage system which drains to Nash Wastewater Treatment Works (WwTW). We have considered the impact of foul flows generated by the proposed development and concluded that flows can be accommodated within the public sewerage system

Turning to surface water drainage, as of 7th January 2019, this proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. In the event this proposed development amounts to a total impermeable area of 100sqm or more, approval of Sustainable Drainage Systems (SuDS) features will be required in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. In this instance, we offer no objection to proposals for disposal of surface water flows into a soakaway, in principle, subject to consultation and agreement with the regulatory body or riparian owner of this system.

In addition, this site is crossed by a public sewer with their approximate positions being marked on the attached statutory public sewer. In accordance with the Water Industry Act 1991, Dwr Cymru Welsh Water requires access to its apparatus at all times in order to carry out maintenance and repairs. Having regard to drawing reference KD1989/1, it appears the proposed development would be situated outside the protection zone of the public sewers measured 3 metres either side of the centreline and therefore acceptable in principle. Please note, the distance specified for this protection zone is indicative and based on industry standard guidelines. However, the depth of the asset will need to be verified on site which may infer a greater protection zone. For completeness, we recommend the developer refer to their title deeds to confirm if there are any covenants or restrictions associated with the assets crossing the proposed development site.

Accordingly, if you are minded to grant planning consent for the above development, we would request that the following **Condition and Advisory Notes** are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets:

Condition

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Advisory Notes

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Phillip Little
Development Planning Officer
Developer Services



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.