


100
10
0
Millimetres

CLASSIFICATION - Baseline (Low Risk)



DO NOT SCALE

- NOTES:
1. DRAWING ONLY TO BE USED FOR THE PURPOSE FOR WHICH IS WAS CREATED.
 2. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.
 3. ALL DRAWINGS SHOULD BE READ IN CONJUNCTION WITH ENGINEERING PACKAGE OF INFORMATION.
 4. ALL SURFACE WATER DRAINAGE IS SUBJECT TO SuDS APPROVAL BODY (SAB) APPROVAL.
 5. FOUL DRAINAGE CONNECTIONS ARE SUBJECT TO SECTION 106 AGREEMENT WITH THE SEWERAGE UNDERTAKER.
 6. THE PEAK FOUL DISCHARGE RATE, BASED ON 50 PERSONS AND 100 LITRES PER HEAD PER DAY USAGE IS CALCULATED TO BE 0.38l/s

SERVICES KEY

- Existing surface water drain
- Existing highway drain
- Existing foul drain
- Proposed surface water drainage network
- Proposed foul drainage network

GENERAL KEY

- Red line boundary
- Client land ownership / leasehold
- Swale / Basin
- Permeable Pavement
- Bioretention System / Rain Garden

Rev.	Date	Description	By	Chk'd	App'd
P04	28/06/23	RIBA STAGE 2+ UPDATE	SF	TR	AM
P03	02/03/21	RIBA STAGE 2+ UPDATE	SF	TR	AM
P02	10/02/21	RIBA STAGE 2+	SF	TR	AM
P01	25/11/19	Stage 2 - Planning	HS	TR	AM

Drawing Status	WORK IN PROGRESS	Suitability	SO
----------------	------------------	-------------	----



SNC-LAVALIN



ATKINS

Member of the SNC-Lavalin Group

The Hub
500 Park Avenue
Aztec West
Bristol
BS32 4RZ

Tel: +44 (0)1454 662000
Fax: +44 (0)1454 663333
www.atkinsglobal.com

© SNC-Lavalin (2023)

Client



VANTAGE
DATA CENTERS

Project Title

NEXT GENERATION DATA

Drawing Title

DRAINAGE
GENERAL ARRANGEMENT

Scale	Designed	Drawn	Checked	Authorised
1:500	HS	TR	TR	AM
Original Size	Date	Date	Date	Date
A1	25/11/2019	25/11/2019	25/11/2019	26/11/2019
Drawing Number	Revision			
5185749-ATK-XX-XX-DR-D-8100				P04

CLASSIFICATION - Baseline (Low Risk)

