

From: Arnall, Guy <Guy.Arnall@newport.gov.uk>
Sent: 01 July 2026 08:51
To: Davidson, Joanne (East Area Development Manager)
<Joanne.Davidson@newport.gov.uk>
Subject: RE: Planning Consultation Request for case ref: 26/0367

Thanks Jo

I was concerned that the external lighting was proposed to be 4000K, which would have potential to create a rather stark lighting regime.

2700 Kelvin as now proposed is a softer and warmer light, which will be more appropriate to this sensitive area.

Many thanks,

Guy Arnall