

DECLARATION OF CONFORMITY

Manufacturer

Name Viltra
Address 56 Damolly Road
Newry, Co. Down
BT34 1QR

OXCRETE 97.5%

**"Small wastewater treatment systems for up to 50 PT - Part 3:
Packaged and/or site assembled domestic wastewater treatment plants"**
According to PIA SR66-1611-1126

Product description	Sewage treatment system
Nominal organic daily load	0.3kg/day
Daily hydraulic flow	0.9m ³ /day
Watertightness (water test)	Pass
Structural behaviour	Pass
Treatment efficiency (nominal sequences)	COD 93.2%
	BOD ₅ 97.5%
	TSS 97.0%
Electrical consumption	0.59kWh/d

Approved body

PIA - Prüfinstitut für Abwassertechnik GmbH
(PIA GmbH)
Hergenrather Weg 30
52074 Aachen, Germany



Notified Body
No.: 1739



Certified according to
ISO 9001:2008



Deutsche
Akkreditierungsstelle
D-PL-17712-01-00