

-----Original Message-----

From: Kimberley, John (Structural Engineer)

Sent: 09 June 2025 15:22

To: NCC - Planning <Planning@newport.gov.uk>

Subject: RE: Planning Consultation Request for case ref: 25/0433

I have added some requirements to the sketch in red provided for ease of explanation.

1. The middle retaining wall must be straight so that it can support the post above suitably. The exposed face can still be sloped as drawn.
2. All walls must stand on suitable foundation strips at least 100mm thick and 200mm beyond the width of the wall on both sides.
3. Consideration should be given to drainage, weep holes through the retaining walls and a gulley at the base perhaps. At all levels.

Other than this there is no objection from structures.

Regards

John