

Re: Rogerstone library heritage officer comments



Moore, Samuel

To: Arnall, Guy; Ostler, Marnie (Planning Officer); Williams, Mark (Library Manager)

Retention Policy 7 Year Delete (7 years)

This message is part of a tracked conversation. Click here to find all related messages or to open the original flagged message.

Expires 01/02/2033



Tue 03/02/2026 13:50

Start your reply all with: [Wonderful, thank you!](#) [Great, thanks!](#) [Perfect, thank you!](#) [Feedback](#)

Hi Guy,

No problem.

I can confirm that the ramp and steps can be coated with this surfacing.

Many thanks,

Sam

Sent from [Outlook for iOS](#)

From: Arnall, Guy <Guy.Arnall@newport.gov.uk>

Sent: Tuesday, February 3, 2026 1:44:34 PM

To: Moore, Samuel <Samuel.Moore@cysoncymru.co.uk>; Ostler, Marnie (Planning Officer) <Marnie.Ostler@Newport.gov.uk>; Williams, Mark (Library Manager) <Mark.Williams@newport.gov.uk>

Subject: RE: Rogerstone library heritage officer comments

Hi Sam

The darkest grey they have would be best, I think.

Many thanks,

Guy Arnall

Prif Swyddog Treftadaeth / Principal Heritage Officer

Swyddog Dirprwyedig (Adeiladau Rhestredig) / Delegated Officer (Listed Buildings)

Adfywio a Datblygu Economaidd / Regeneration and Economic Development

Cyngor Dinas Casnewydd / Newport City Council

E: Guy.Arnall@newport.gov.uk | Planning@newport.gov.uk

From: Moore, Samuel <Samuel.Moore@cysoncymru.co.uk>


Sent: 03 February 2026 13:43

To: Arnall, Guy <Guy.Arnall@newport.gov.uk>; Ostler, Marnie (Planning Officer) <Marnie.Ostler@Newport.gov.uk>; Williams, Mark (Library Manager) <Mark.Williams@newport.gov.uk>

Subject: Re: Rogerstone library heritage officer comments

Hi Guy,

Apologies. Hopefully the attached can be viewed by yourself. Will the grey amongst these options still be suitable?



Many thanks,

Sam

Re: Rogerstone library heritage officer comments



Moore, Samuel


To Ostler, Marnie (Planning Officer)

Cc Williams, Mark (Library Manager); Arnall, Guy

Retention Policy 7 Year Delete (7 years)

Expires 31/01/2033

This message is part of a tracked conversation. [Click here](#) to find all related messages or to open the original flagged message.



Just to add to my previous email, I can confirm that a suitable specialist coating has been suggested.

We would opt for CooVar Zinc Phosphate Primer followed by CooVar Suregrip as well as a mordent solution.

This coating comes in the following colour options so we would be open to Guy's suggestion on which he would deem the most suitable...

