

Newport County
Civic Centre
NEWPORT
NP20 4UR

Date: 08/06/2026
Our Ref: PLA0095482
Your Ref: 26/0185

Dear Sir

Grid Ref: ST314851 331504 185208

Site: B16 W Way Road Newport

Development: NEW INDUSTRIAL BUILDING TO HOUSE PALLET MANUFACTURING AND REPAIR FACILITIES TOGETHER WITH EXTERNAL MATERIALS AND PALLET STORAGE AREAS INCLUDING STORAGE SHELTER AND ASSOCIATED FACILITIES

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

Firstly, with respect to the submitted application form, we acknowledge that the development proposes to discharge foul and surface water flows to a septic tank and soakaways respectively. Since the proposal intends utilising an alternative to mains drainage for foul water, we would advise that the applicant seek advice from Natural Resources Wales and/or the Building Regulations Authority as the regulatory body for this method of drainage. Should circumstances change and a connection to the public sewerage system is preferred, we must be re-consulted on this application. Turning to surface water drainage, as of 7th January 2019, this proposed development is subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore requires approval of Sustainable Drainage Systems (SuDS) features, in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. In this instance, we offer no objection to proposals for disposal of surface water flows into a soakaway, in principle, subject to consultation and agreement with the regulatory body or riparian owner of this system. Accordingly, if you are minded to grant planning consent for the above development, we would request that the following Advisory Notes are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets:

Advisory Notes *The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water Industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and*

conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water on 0800 085 3968 to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times. The planning permission hereby granted does not extend any rights to carry out any works to the public sewerage or water supply systems without first having obtained the necessary permissions required by the Water industries Act 1991. Any alterations to existing premises resulting in the creation of additional premises or merging of existing premises must also be constructed so that each is separately connected to the Company's water main and can be separately metered. Please contact our new connections team on 0800 917 2652 for further information on water & sewerage connections. In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements. Dwr Cymru Welsh Water is not responsible for fire protection or for providing suitable fire flows. Providing fire flows and fire protection are the responsibility of the appropriate regional Fire Services. We refer you to the 3rd Edition of the National Guidance Document on the Provision of Water for Fire Fighting published by the Local Government Association and Water UK

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,
Phillip Little
Development Planning Officer
Developer Services



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.