

Ref: LBC/19/00686 – TSD03

Date: 20/08/2025

MATERIAL SAMPLES CONDITION: CONDITION 2 APPLICATION – SHIREHALL REF: LBC/2019/00686

Please find below photographs taken of the samples of materials proposed for the DARK ASH STONE POINTINGS of the pennant / lias (grey / brown colour) stone areas / facades and the rear (North elevation) Yellow stock Brickworks at the above applicant site:



Plate 1: Existing pointings (lias panels)



Plate 2: Trial sections of stone repointing (1:3:1 NHL2.5 / Blaenavon Dark / washed sharp sand)



Plate 3: Existing yellow stock brick pointings



Plate 4: Trial sections of repointing to brickworks (1:3:1 NHL2.5 / Blaenavon Dark / washed sharp sand)

Pointings to be replaced where missing / defective to pennant / lias stone panels (all elevations) and yellow stock brickwork on rear (North) elevations of Shirehall on a matched like for like basis.